

Salvatore D. Janiero

16 Chestnut Street, Suite 220 Foxboro, MA 02035 Tel (401) 533-0728 Fax (774) 215-5423

Melanie Bachman Acting Executive Director Connecticut Siting Council 10 Franklin Square New Britain, CT 06051



Re: Notice of Exempt Modification - Emergency Backup Generator FA#: 10126686/ 35 Old Route 44, Eastford, CT 06242 Project Code: 2051691590

Dear Ms. Bachman:

American Telephone and Telegraph Company ("AT&T") currently maintains a wireless telecommunications facility at the above referenced address. AT&T's facility consists of antennas at the 150' mark of the existing 193' tower and an existing AT&T equipment shelter. The tower and AT&T's shelter are located within an existing lease area. The pad supports AT&T's equipment and space for a back-up generator. AT&T does not currently maintain a generator at this cell site.

In an effort to further enhance multiple tenants' network reliability, AT&T intends to modify its facility by installing a new 50kw diesel-powered generator outside in a designated 4'x8' ground space. The diesel fuel tanks are double walled for added safety and will be filled by a licensed fuel filling company. The proposed modification will be within the fenced compound within the limits of the existing lease area. The new generator and tank will be surrounded by a matching security fence and gate. (See Facility Compound Plan attached).

Please accept this letter as notification pursuant to R.C.S.A Section 16-50j-73, for construction that constitutes modification pursuant to R.C.S.A Section 16-50j-72(b)(2). In accordance with R.C.S.A Section 16-50j-73, a copy of this submission is being sent to the Town of Eastford. A copy of this submission is also being sent to Priscilla D. Armitage, the property owners on which the tower is located.

ATCs' Proposed Wireless Modifications Constitutes An "Exempt Modification"

The proposed modification to the above mentioned Facility constitutes an exempt modification of an existing facility provided for in R.C.S.A Section 16-50j-72(b)(2) and Council regulations promulgated pursuant thereto.

1) The proposed modification will not result in an increase in the height of the existing tower.

- 2) The generator and attached fuel tank will remain entirely within the limits of the leased area. The modifications therefor, will not require the extension of the boundary.
- 3) The proposed modification does not increase the noise levels at the boundary by six(6) decibels or more under normal conditions. Proposed modification is only used during emergency power failure.
- 4) The installation of a new generator and attached fuel tank will not change, in any way, radio frequency (RF) emissions at the facility.
- 5) The facility has received all municipal zoning approvals and building permits. (Regs., Conn. State Agencies Section 16-50j-72))

For all the foregoing reasons, American Telephone and Telegraph Company respectfully submits that the proposed modifications to the above-referenced telecommunications facility constitutes an exempt modification under R.C.S.A Section 16-50j-72(b)(2)

Respectfully submitted,

Sal laniero 401-533-0728

On behalf of American Tower Corporation


c/o) Tower Resource Management, Inc.

16 Chestnut Street, Suite 220

Foxboro, MA 02035

cc: Town of Eastford, CT Priscilla D. Armitage Exhibit 1

Site Plan






BYCK F POSITR ROJECT

SITE IDENTIFICATION:

SITE NUMBER: 10126686 SITE NAME: EASTFORD CT OLD RT 44

SITE ADDRESS: 35 OLD ROUTE 44

EASTFORD, CT 06242



LOCAL MAP

IF MUX LOCATION IS OUTSIDE OF AT&T EQUIPMENT AREA, CONTRACTOR IS TO FIELD VERIFY THE PRESENCE OF EMERGENCY BACK-UP SERVICE TO THE MUX. IF EMERGENCY BACK-UP SERVICE IS NOT PRESENT, CONTRACTOR IS TO ROUTE NEW SERVICE FROM AT&T EQUIPMENT ARE NOTE:
CONTRACTOR TO VERIFY EXISTING MUX LOCATION

PROJECT DESCRIPTION:



ATRT MORILITY
550 COCHITUATE ROAD
SUITES 13 & 14
FRARINGHAM, MA 01701

know what's below. Call before you dig.

PROJECT

TEAM









10126686

EASTFORD CT RT 44 SITE NAME: OLD

SITE ADDRESS; 35 OLD ROUTE 44 EASTFORD, CT 06242

LANDLORD: CORDLESS DATA TRANSFER 600 DED HARTFORD RD COUCHESTER, CT 06413

CORDLESS DATA TRANSFER 800 OLD HARTEGRE RD COLCHESTER, CT 08415

GROUND OWNER:

NAME: NORTHEAST UTILITIES

WARKET LEAD - AT®T NE GENERATOR PROGRAM
L3013 WORRIS ROAD, 6TH FLOOR, BLDG 1
ALPHARETTA, GA 30004
CE__ 770-995-0137

SABRE INDUSTRIES

CUSTOMER REPRESENTATIVE:

ppoor@sabreindustries.com

TO OPEN A TAP TICKET DIAL: 1-800-638-2822 SELECT OPTION 1, THEN OPTION 2

TOWARDS OLD COLONY RD 30 TT, SLEGHT LEFT ONTO CT-198 S/EASTFORD RD 1.8 MI, TURN LEFT ONTO U.S. 44 E/POWERET RD 1.0 MI, TURN RIGHT ONTO OLD RTE 44 6.2 MI.

LOCATION DIRE

NEED 24 HOUR NOTICE

AT&T OPS FOR POWER CUT OVER:

5. HANDICAP ACCESS IS NOT REQUIRED

GENERATOR ASSEMBLY AND INSTALLATION SUPPLEMENT

103 \0: [12	ATE DRAWN: 1-	THECKED BY: SB	DRAWN BY: RJ
1262.01	-21-14		

TITLE SHEET VICINITY MAP AND GENERAL INFORMATION

SHEET NUMBER! REV. #

0

